Relay Protection Time Relay Experiment

Overview

Electrical Protection Lab Experiments | PDF | Relay The document outlines a series of experiments for a VI Semester B.Tech (EEE) Electrical Protection Labo.

Key Takeaways

A Time Relay Protection Experiment studies the operation of time-based protective relays, such as IDMT overcurrent relays, by analyzing their time-current characteristics and settings to ensure proper fault protection.

Objective

The main goal of a time relay protection experiment is to understand how protective relays respond to overcurrent conditions and to verify their time-current characteristics. This ensures that faults in a power system are cleared promptly while maintaining coordination with other protective devices. Key ComponentsIDMT Overcurrent Relay: Operates when current exceeds a preset threshold; the operating time decreases as the current increases relative to the set value.

Current Transformer (CT): Steps down the line current to a measurable value for the relay. Circuit Breaker: Interrupts the circuit when the relay operates. Time Setting Multiplier (TSM) and Plug Setting Multiplier (PSM): Adjust the relay's operating time and sensitivity to current.

Experimental Procedure

© 2026 CJC FIBRE CONSULTANTS - All rights reserved

Relay Setting: Set the relay pickup current (e.g., 5A) and select the desired time characteristic (definite, inverse, or very inverse) using TSM and PSM. Fault Simulation: Apply overcurrent conditions using a variable current source to simulate faults. Measurement: Record the operating time of the relay for different multiples of the pickup current.

Plotting Characteristics: Draw the time-current characteristic curve with current on the X-axis (as a multiple of pickup current) and operating time on the Y-axis. This helps visualize the inverse relationship between current magnitude and relay operating time. Coordination Study: Compare curves of series-connected relays to ensure proper coordination, avoiding overlap that could cause misoperation.

Observations and Analysis

The relay should not operate below the pickup current. Operating time decreases as the current increases above the set threshold. The experiment demonstrates inverse time behavior, where higher fault currents result in faster relay operation.

Proper coordination ensures that upstream relays operate after downstream relays, isolating only the faulted section.

Applications

Protection of radial feeders, transformers, and generators. Ensuring selective tripping in power distribution systems. Understanding relay coordination and system reliability.

This experiment provides hands-on experience with protective relay operation, time-current characteristics, and fault response, which are essential for designing and maintaining safe and reliable power systems.

Article Content

Electrical Protection Lab Experiments | PDF | Relay

The document outlines a series of experiments for a VI Semester B.Tech (EEE) Electrical Protection Laboratory, focusing on various relay characteristics and protection schemes.

POWER SYSTEM PROTECTION LAB I YEAR II SEM M.Tech (Power

An undervoltage relay is one that operates when input voltage drops below a predetermined value(dropout value).Undervoltage relays are usually instantaneous devices.If time delays are

Power System Protection and Switchgear Lab

© 2026 CJC FIBRE CONSULTANTS - All rights reserved

Study of Over-Current relay—To find time-current characteristics of IDMT relay with different time settings and plug settings. To perform experiment on under/over voltage protection.

PSP Lab Experiments 1-6: IDMT Relay & Protection Studies

This document outlines laboratory experiments focused on various electrical protection relays, including IDMT Over Current, Differential, and Negative Sequence relays. It details objectives, apparatus,

An Experimental Setup for Power System Protection in Electrical ...

In this paper we have discussed a various protective schemes with testing electromechanical relay. Through this practical set-up, the students can get familiar with the fundamentals of protection and

EE 101: Laboratory Experiments on Relay Protection Systems

This document outlines various electrical engineering experiments, including the operation of overcurrent relays, testing of circuit breakers, and the study of distance protection relays.

Exp. 1: Inverse Definite Minimum Time (IDMT) Over Current Relay

On completion of this experiment, participants will be able to understand working of numerical over current relay and plot its inverse time/current characteristics with definite minimum time

Ahsanullah University of Science and Technology

The relays are built to be self protecting in the event of an overload until the short circuit protection device is activated. To make a fine adjustment, change the distance between the heater and the heat

Power System Protective Relays: Principles & Practices

Abstract: Protective relays and devices have been developed over 100 years ago to provide “last line” of defense for the electrical systems. They are intended to quickly identify a fault and isolate it so the

POWER SYSTEMS LAB EE-328-F

Aim: To draw the operating characteristics of IDMT relay Objective: The aim of the experiment to investigate the operation, inverse characteristics and to determine the purpose of time and plug

Protection Relays Numbering (ANSI) | PDF

© 2026 CJC FIBRE CONSULTANTS - All rights reserved

This document lists standard electrical power system device function numbers from ANSI C37.2. It includes 99 device functions numbered 1 through 99 with descriptions such as master element, time

IDMT Overcurrent Relay Characteristics

The experiment involves applying various fault currents using a current injection transformer and measuring the operating times of the relay at different plug and time setting multiplier settings. The

Time Lag Earth Fault Relay Testing Guide

This document provides instructions for testing a time lag earth fault relay. It describes: 1. The objectives of identifying time lag earth fault relay settings and studying protection of equipment using relays. 2.

IDMT Relay Protection System Design

The document describes an experiment to design an overcurrent protection system using an inverse definite minimum time (IDMT) relay and plot the operating time characteristics of the relay. Key steps

An Experimental Setup for Power System Protection in Electrical ...

Abstract: The protective systems are essential for the Protection of Power distribution and Radial Feeder System. In this paper we have discussed a various protective schemes with testing

Undervoltage/Overvoltage Relay Experiment

This document describes an experiment to test undervoltage and overvoltage time lag relays in a three-phase power system. The objectives are to investigate the relay''s behavior under different voltage

Exp. 1: Inverse Definite Minimum Time (IDMT) Over Current Relay

1.To plot inverse definite minimum time characteristics of numerical over current relay. 2.To perform experiment on definite / instantaneous mode setting of the relay.

Relay Settings for Radial Feeder Protection

The experiment aims to demonstrate protection of a simulated radial transmission line divided into three sections using overcurrent relays with different inverse time characteristics (normal, very, and

Related Video Reference

This video was associated with the source search result. Verify technical details against current product documentation and project requirements.

© 2026 CJC FIBRE CONSULTANTS - All rights reserved

Contact Us

Continue your research online:

Website: https://cjcconsultants.co.za
Technical inquiry: https://cjcconsultants.co.za/contact.html

This document is for preliminary research. Verify specifications against current standards, product documentation and project requirements.

© 2026 CJC FIBRE CONSULTANTS - All rights reserved